

# Missouri Department of Natural Resources



## PUBLIC NOTICE

### DRAFT MISSOURI STATE OPERATING PERMIT

DATE: July 7, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, Missouri 65102, ATTN: NPDES Permits and Engineering Section / Permit Comments. **Please include the permit number in all comment letters.**

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curd v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by August 7, 2006 or received in our office by 5:00 p.m. on August 10, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.mo.gov/env/wpp/index.html>, or at the Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, Missouri 65102, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: July 7, 2006


Permit Number: MO-0047031

Southeast Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
<b>Facility Name:</b> Rolla, Vichy Road WWTP <b>Address:</b> 11751 County Road 8030, Rolla, MO 65401	<b>Owner:</b> City of Rolla <b>Address:</b> P.O. Box 979, Rolla, MO 65402
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
<b>Receiving Stream:</b> Unnamed Tributary of Spring Creek (U) <b>Legal Description:</b> NW ¼, NE ¼, Sec. 35, T38N, R8W, Phelps County	

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**

MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0047031

Owner: City of Rolla  
Address: P.O. Box 979, Rolla, MO 65402

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Rolla, Vichy Road WWTP  
Address: 11751 County Road 8030, Rolla, MO 65401

Legal Description: NW ¼, NE ¼, Sec. 35, T38N, R8W, Phelps County

Receiving Stream: Unnamed Tributary of Spring Creek (U)  
First Classified Stream and ID: Spring Creek (P)(01534)  
USGS Basin & Sub-watershed No.: (10290203 - 020003)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

Outfall #001 – POTW- SIC #4952

Contact Stabilization/aerobic digester/trickling filter/  
sludge storage basin/sludge is land applied.  
Design population equivalent is 4,000.  
Design flow is 400,000 gallons per day.  
Actual flow is 300,000 gallons per day.  
Design sludge production is 100 dry tons/year.

Outfall #002 – POTW – SIC #4952

Infiltration and Inflow Clarifier.  
Design flow is 3 million gallons per day.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Doyle Childers, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

Expiration Date  
MO 780-0041 (10-93)

Edward Galbraith, Director of Staff, Clean Water Commission

<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>					PAGE NUMBER 2 of 8	
					PERMIT NUMBER MO-0047031	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/week	24 hr. total
Biochemical Oxygen Demand <sub>5</sub> **	mg/L		45	30	once/month	24 hr. composite
Total Suspended Solids**	mg/L		45	30	once/month	24 hr. composite
pH – Units	SU	***		***	once/ month	grab
Ammonia as N (May 1 – Oct 31)	mg/L	3.7		1.9	once/month	grab
(Nov 1 – April 30)	mg/L	7.5		3.7		
Oil and Grease						
	μg/L	15		10	once/month	grab
Cadmium, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
Copper, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
Lead, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
Nickel, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
Silver, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
Zinc, Total Recoverable	μg/L	*		*	once/quarter	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Outfall #001</u> (Note 1)						
Whole Effluent Toxicity (WET) Test	% Survival		(See Special Conditions)		once/year	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>ANNUALLY</u> . THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Outfall #002</u>						
Flow	MGD	*		*	once/day****	24 hr. total
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45		once/event****	grab
Total Suspended Solids	mg/L		45		once/event****	grab
Ammonia as N	mg/L	*		*	once/event****	grab
pH	SU	***		***	once/event****	grab
Temperature	°F	*		*	once/event****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II, &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b> (continued)					PAGE NUMBER 3 of 8	
					PERMIT NUMBER MO-0047031	
<p>The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:</p>						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Instream Monitoring</u> (Note 2)						
Ammonia as N	mg/L	*		*	once/month	grab
pH	SU	*		*	once/month	grab
Temperature	°F	*		*	once/month	grab
Dissolved Oxygen	mg/L	*		*	once/month	grab
Hardness, Total	mg/L	*		*	once/month	grab
<p>MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u>; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.</p>						
<b>B. STANDARD CONDITIONS</b>						
<p>IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II, &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u>, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.</p>						

MO 780-0010 (8/91)

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS** (continued)

- \* Monitoring requirement only.
- \*\* This facility is required to meet a removal efficiency of 85% or more.
- \*\*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.
- \*\*\*\* The sampling location shall be following the effluent weir for outfall #002, and prior to mixing with the effluent from outfall #001.

Note 1 - WET testing will be conducted once/quarter, in the months of January, April, July, and October, during the first year following issuance of the permit, and annually thereafter. Testing for the first year will consist of alternating multiple dilution tests and single dilution tests for Outfall #001.

Note 2 – Instream monitoring will be conducted approximately one tenth (0.1) mile downstream of the plant outfall.

**C. SPECIAL CONDITIONS**

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list. The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

C. SPECIAL CONDITIONS (continued)

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. **Changes in Discharges of Toxic Substances**  
The permittee shall notify the Director as soon as it knows or has reason to believe:
  - (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
    - (1) One hundred micrograms per liter (100 µg/L);
    - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
    - (4) The level established in Part A of the permit by the Director.
  - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.
6. **Water Quality Standards**
  - (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
  - (b) **General Criteria.** The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
    - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
    - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
    - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
    - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
    - (5) There shall be no significant human health hazard from incidental contact with the water;
    - (6) There shall be no acute toxicity to livestock or wildlife watering;
    - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
    - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
7. **Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities**
  - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
  - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. The permittee shall submit a report semi-annually with the Discharge and Monitoring reports in January and July which address measures taken to locate and eliminate sources of infiltration and inflow into the City's collection system.

C. SPECIAL CONDITIONS (continued)

9. Whole Effluent Toxicity (WET) tests shall be conducted as follows:

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALLS	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH
001	100 (see Note 1)	annually (see Note 1)	24 hr composite	August

(a) Test Schedule and Follow-Up Requirements

- (1) Perform a SINGLE-dilution test in the months and at the frequency specified above. For tests which are successfully passed, submit test results USING THE DEPARTMENT'S WET TEST REPORT FORM #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
  - (a) For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
  - (b) Samples submitted for analysis of stormwater discharges shall be collected as a grab.
  - (c) For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation.
  - (d) A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
  - (e) Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
  - (f) Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
  - (g) Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
  - (h) Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
  - (i) All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.
  - (j) Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
  - (k) Where in stream testing is required downstream from the discharge, sample collection shall occur immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.
  - (l) Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
  - (m) All instream samples, including downstream samples, shall be tested for toxicity at the 100% concentration in addition to any other assigned AEC for in-stream samples.
- (2) All failing test results along with complete copies of the test reports as received from the laboratory, INCLUDING THOSE TESTS CONDUCTED UNDER CONDITION (3) BELOW, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
- (3) If the effluent fails the test, a multiple dilution test shall be performed within 30 calendar days and biweekly thereafter, until one of the following conditions are met:
  - (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
  - (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.

C. SPECIAL CONDITIONS (continued)

9. Whole Effluent Toxicity tests (continued):

- (4) Failure of at least three multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.
- (5) The permittee shall submit a CONCISE summary of all test results for the test series to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
- (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
- (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
- (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
- (8) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the Department's WET test report form that was generated during the reporting period.
- (9) Submit a concise summary in tabular format of all test results with the annual report.

(b) PASS/FAIL procedure and effluent limitations:

- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other Federal guidelines as appropriate or required.
- (2) To pass a multiple-dilution test:
  - (a) For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC), OF 30% OR LESS THE AEC must be less than three-tenths (0.3) of the  $LC_{50}$  concentration for the most sensitive of the test organisms; OR,
  - (b) For facilities with an AEC greater than 30% the  $LC_{50}$  concentration must be greater than 100%; AND,
  - (c) all effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.

(c) Test Conditions

- (1) Test Type: Acute Static non-renewal
- (2) Test species: Ceriodaphnia dubia and Pimephales promelas (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS.
- (3) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (4) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.



C. SPECIAL CONDITIONS (continued)

9 . Whole Effluent Toxicity tests (continued):

- (5) Single-dilution tests will be run with:
  - (a) Effluent at the AEC concentration;
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (6) Multiple-dilution tests will be run with:
  - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
- (8) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

## SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

### Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$ )
Test acceptability criterion:	90% or greater survival in controls

### Test conditions for Pimephales promelas:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$ )
Test Acceptability criterion:	90% or greater survival in controls



Missouri Department of Natural Resources  
Water Protection Program  
Water Pollution Control Branch  
NPDES Permits and Engineering Section

## Water Quality Review Sheet Determination of Effluent Limits

### Facility Information

FACILITY NAME: Rolla, Vichy Road WWTF NPDES #: MO-0047031

FACILITY TYPE/DESCRIPTION: Contact stabilization, aerobic digester, trickling filter

ECOREGION: Ozark Highlands 8- DIGIT HUC: 10290203 COUNTY: Phelps  
Central Irregular Plains Interior River Valleys and Hills Ozark Highlands  
Mississippi Alluvial & Loess Plains Western Corn Belt Plains

LEGAL DESCRIPTION: NW ¼, NE ¼, Sec. 35, T38N, R8W LATITUDE/LONGITUDE: +3758364/ -9146214

WATER QUALITY HISTORY: Impacts to receiving stream for the past 10 years. Reduced benthic diversity below  
outfall in 2004. Unknown toxicity. Ammonia usually less than 1 mg/L  
Mostly in compliance with effluent limits, some exceedances for high pH.

### Outfall Characteristics

OUTFALL	DESIGN FLOW (CFS)	TREATMENT TYPE	RECEIVING WATERBODY	OTHER
001	0.62	Secondary	Unnamed tributary to Spring Creek	
002	varies	Primary	Unnamed tributary to Spring Creek	

### Receiving Waterbody Information

WATERBODY	CLASS	7Q10(CFS)	*DESIGNATED USES	OTHER CHARACTERISTICS
Unnamed tributary to Spring Creek	U	0.0	General Criteria only	
Spring Creek	P	0.1	LWW, AQL	WBID: 03560

\*Cool Water Fishery (CLF), Cold Water Fishery (CDF), Irrigation (IRR), Industrial (IND), Boating & Canoeing (BTG), Drinking Water Supply (DWS), Whole Body Contact Recreation (WBC), Protection of Warm water Aquatic Life and Human Health (AQL), Livestock & Wildlife Watering (LWW)

COMMENTS: Approximately 3.25 miles to classified portion of Spring Creek.

### MIXING CONSIDERATIONS

**Mixing Zone (MZ).** Receiving stream is unclassified, therefore no mixing zone is allowed. Acute criteria apply per 10 CSR 20-7.031(3)(I)1. and chronic criteria must be met at the classified segment of Spring Creek.

**Zone of Initial Dilution (ZID).** Receiving stream is unclassified, therefore no mixing zone is allowed. Acute criteria must be met end-of-pipe

## Permit Limits and Information

TMDL WATERSHED:  W.L.A. STUDY CONDUCTED:  DISINFECTION REQUIRED:  USE ATTAINABILITY ANALYSIS:

### OUTFALL# 001

WET TEST (Y OR N):  FREQUENCY: ONCE/QUARTER A.E.C. 100% LIMIT: 10 CSR 20-7. 031(3)(I)

$$\text{A.E.C. \%} = \left( \frac{\text{Design Flow} + \text{Zone of Initial Dilution}}{\text{Design Flow}} \right)^{-1} \times 100$$

PARAMETER	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MONITORING FREQUENCY
FLOW	MONITOR			total once/day
BOD <sub>5</sub> (MG/L)		45	30	once/month
TSS (MG/L)		45	30	once/month
PH (S.U.)	6-9		6-9	once/month
AMMONIA AS N (MG/L) (MAY 1 – OCT 31)	3.7		1.9	once/month
AMMONIA AS N (MG/L) (NOV 1 – APR 30)	7.5		3.7	once/month
OIL & GREASE (MG/L)	15		10	once/month
CADMIUM, TOTAL RECOVERABLE	MONITOR			once/quarter
COPPER, TOTAL RECOVERABLE	MONITOR			once/quarter
LEAD, TOTAL RECOVERABLE	MONITOR			once/quarter
NICKEL, TOTAL RECOVERABLE	MONITOR			once/quarter
SILVER, TOTAL RECOVERABLE	MONITOR			once/quarter
ZINC, TOTAL RECOVERABLE	MONITOR			once/quarter

### OUTFALL# 002

WET TEST (Y OR N):  FREQUENCY: \_\_\_\_\_ A.E.C. \_\_\_\_\_ LIMIT: \_\_\_\_\_

PARAMETER	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MONITORING FREQUENCY
FLOW	MONITOR			once/day
BOD <sub>5</sub> (MG/L)		45		once/month
TSS (MG/L)		45		once/month
PH (S.U.)	6-9		6-9	once/month
AMMONIA AS N (MG/L)	*			once/month
TEMPERATURE	*			once/month

## Receiving Water Monitoring Requirements

### Site S1 Instream monitoring

PARAMETER(S)	SAMPLING FREQUENCY	SAMPLE TYPE	LOCATION
AMMONIA AS N	ONCE/MONTH	GRAB	APPROXIMATELY .1 MILES BELOW OUTFALL
pH	ONCE/MONTH	GRAB	APPROXIMATELY .1 MILES BELOW OUTFALL
TEMPERATURE	ONCE/MONTH	GRAB	APPROXIMATELY .1 MILES BELOW OUTFALL
DISSOLVED OXYGEN	ONCE/MONTH	GRAB	APPROXIMATELY .1 MILES BELOW OUTFALL
HARDNESS, TOTAL	ONCE/MONTH	GRAB	APPROXIMATELY .1 MILES BELOW OUTFALL

Please report the date, time, and location for each parameter sampled along with the average daily flow (actual flow measured or estimated, not design flow). All the parameters should be sampled on the same day and within no more than a 2-hour period. Dissolved oxygen (DO) measurements are to be taken during the period from one hour prior to sunrise to one and one-half hour after sunrise. If discharge is contingent to storm events, rainfall should be measured every time there is a discharge.

## Derivation and Discussion of Limits

Wasteload allocations (WLA) were calculated using water quality criteria and the dilution equation below:

$$C = \frac{(C_s * Q_s) + (C_e * Q_e)}{(Q_e + Q_s)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration

C<sub>s</sub> = upstream concentration

Q<sub>s</sub> = upstream flow (cfs)

C<sub>e</sub> = effluent concentration

Q<sub>e</sub> = effluent flow (cfs)

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable acute water quality criteria (CMC: criteria maximum concentration) and stream volume of flow.

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

### Outfall 001

- **Biochemical Oxygen Demand (BOD<sub>5</sub>)** 30 mg/L monthly average, 45 mg/L weekly average [10 CSR 20-7.015(8)(B)1.]
- **Total Suspended Solids (TSS)** 30 mg/L monthly average, 45 mg/L weekly average [10 CSR 20-7.015(8)(B)1.]
- **pH** pH shall be maintained in the range from six to nine (6 – 9) standard units [10 CSR 20-7.015(8)(B)2.]
- **Ammonia as Nitrogen** Total Ammonia Nitrogen – Early Life Stages Present criteria apply 10 CSR 20-7.031(4)(B)7.C. & Table B3. Background ammonia as nitrogen for receiving stream is assumed to be = 0.01mg/L.

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
Summer	26	7.8	1.5	12.1
Winter	6	7.8	3.1	12.1

Summer: May 1 – October 31, Winter: November 1 – April 30

$$C_e = ((Q_e + Q_s)C - (Q_s * C_s))/Q_e$$

#### Summer

Chronic

$$C_e = ((0.62 + 0.0)1.5 - (0.0 * 0.01))/0.62$$

$$C_e = 1.5 \text{ mg/L}$$

$$WLA_c = 1.5$$

Acute

$$C_e = ((0.62 + 0.0)12.1 - (0.0 * 0.01))/0.62$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 1.5(0.780)=1.2$$

[CV = 0.6, 99<sup>th</sup> Percentile, n=30]

$$LTA_a = 12.1 (0.321)=3.9$$

[CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 1.2(3.11)=3.7$$

[CV = 0.6, 99<sup>th</sup> Percentile]

$$AML = 1.2(1.55)=1.9$$

[CV = 0.6, 95<sup>th</sup> Percentile, n = 4]

#### Winter

Chronic

$$C_e = ((0.62 + 0.0)3.1 - (0.0 * 0.01))/0.62$$

$$C_e = 3.1 \text{ mg/L}$$

$$WLA_c = 3.1 \text{ mg/L}$$

Acute

$$C_e = ((0.62 + 0.0)12.1 - (0.0 * 0.01))/0.62$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 3.1(0.780)=2.4$$

[CV = 0.6, 99<sup>th</sup> Percentile, n=30]

$$LTA_a = 12.1(0.321)=3.9$$

[CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 2.4(3.11)=7.5$$

[CV = 0.6, 99<sup>th</sup> Percentile]

$$AML = 2.4(1.55)=3.7$$

[CV = 0.6, 95<sup>th</sup> Percentile, n = 4]

- **Oil & Grease** Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- **Total Recoverable Cadmium, Copper, Lead, Nickel, Silver, and Zinc** Monitoring only. Data must be gathered for the purposes of developing local pretreatment limits, conducting reasonable potential analysis, and determining source of toxicity in the receiving stream.

#### Outfall 002

- **Biochemical Oxygen Demand (BOD<sub>5</sub>)** 45 mg/L weekly average [10 CSR 20-7.015(8)(B)3.E.(I)]
- **Total Suspended Solids (TSS)** 45 mg/L weekly average [10 CSR 20-7.015(8)(B)3.E.(I)]

- **pH** pH shall be maintained in the range from six to nine (6 – 9) standard units [10 CSR 20-7.015(8)(B)3.E.(II)]
- **Ammonia as Nitrogen**. Monitoring only to determine ammonia contributions from this outfall.

#### **Receiving Water Monitoring Requirements**

- **Ammonia as Nitrogen, Hardness, Dissolved Oxygen, pH and Temperature** Monitoring only to determine instream water quality, and evaluate contributions to the instream toxicity issues previously noted.

Reviewer: Curt Gateley  
Date: 8-30-05, Revised 6-12-06  
Unit Chief: Refaat Mefrakis

Monitoring and effluent limits contained within this document have been developed in accordance with EPA guidelines using the best available data and are believed to be consistent with Missouri's Water Quality Standards and Effluent Regulations. If additional water quality data are available that may affect the recommended monitoring and effluent limits, please forward these data and information to the author.